

FUEL TRUCKS (JP-8) STORAGE (Fuel Tankers/HEMMT/PODS)

GENERAL INFORMATION

Mobile fuel storage in quantities greater than 50 gallons and all fuel transfer operations are prohibited while in Garrison in accordance with the USAG-HI Spill Prevention, Control and Countermeasures Plan (SPCCP). Requests for storage of greater than 50 gallons and any fuel transfer operation must be approved by the DPW Environmental Division by submitting a waiver request to the Clean Water Program.

POTENTIAL HAZARDS

JP-8 is a DOT flammable material and should be handled in accordance with appropriate safety guidelines. Storage of large quantities of JP-8 presents a potential risk to the storm water system. Preventive measures (i.e. secondary containment) must be in place prior to conducting any fuel storage or transfer operations.

WASTE CHARACTERIZATION

Used JP-8 is a recyclable material. Non-saturated absorbent pads and rags with JP-8 are Non-Regulated Waste.

HANDLING AND DISPOSAL PROCEDURES

Step 1: Contact the DPW Environmental Division Clean Water Program for authorization to store more than **50** gallons of fuel or to conduct fuel transfer operations.

Step 2: Fuel trucks containing more than 50 gallons must be protected with a secondary containment system.

Step 3: Used JP-8 and used JP-8 rags/pads should be managed in the facility's RMSSP.



For more info contact: DPW Environmental Clean Water program.